

POWER TRANSFORMER
 (AUTO-TRANSFORMER / TWO-WINDING TRANSFORMER)

Page
 1 of 3

TEST DATA

Test Data No.				MVA
Station				kV HV <input type="checkbox"/> <input checked="" type="checkbox"/> Y [] <input type="checkbox"/> <input checked="" type="checkbox"/> Δ []
Equipment ID				LV <input type="checkbox"/> <input checked="" type="checkbox"/> Y [] <input type="checkbox"/> <input checked="" type="checkbox"/> Δ []
Date of Test				
Make				Winding Connection _____
Serial No				% Impedance _____
Tap Changer Type				Year Manufactured _____

I. EXCITATION CURRENT TEST

HV TAP	EXITING CURRENT (mA) at 10 KV			RATING (S, P, C)
	H1 - H0	H2 - H0	H3 - H0	

Standards Used: _____

Remarks: _____

II. OVERALL INSULATION POWER FACTOR TEST

INSULATION MEASURED	TEST KV	CURRENT mA	WATT-LOSS	% POWER FACTOR		CORRECTION FACTOR	CAPACITANCE pF	RATING (S, P, C)
				Measured	Corrected			
CH + CHT								
CH								
CHT (UST)								
CT + CHT								
CT								
CHT (UST)								

Standards Used: _____

Remarks: _____

III. TRANSFORMER TURNS RATIO TEST

TAP CHANGER POSITION: As Found High _____ Low _____

A. HIGH VOLTAGE - LOW VOLTAGE

HV		LV		Comp Ratio	$H1H0$ X1X0	%E	$H2H0$ X2X0	%E	$H3H0$ X3X0	%E	Rating (S, P, C)
Tap	Volts	Tap	Volts								

Standards Used: _____

Remarks: _____

POWER TRANSFORMER TEST DATA

Page 2 of 3

B. HIGH VOLTAGE - TERTIARY VOLTAGE

HV		TV		COMP RATIO	<u>H1H0</u> y_y_-	%E	<u>H2H0</u> y_y_-	%E	<u>H3H0</u> y_y_-	%E	Rating (S, P, C)
Tap	Volts	Tap	Volts								

Standards Used: _____

Remarks: _____

IV. INSULATION RESISTANCE TEST

PARTS MEASURE D	TEST KV	TEMP	MEGOHMS			MΩ/KV	POLARIZATION INDEX	RATING (S, P, C)
			30 SEC	1 MIN	10 MIN			
HV-Case								
HV-TV								
TV-Case								

Standards Used: _____

Remarks: _____

V. WINDING RESISTANCE TEST

WINDING	TAP	WINDING MEASURED	RESISTANCE (mΩ) corrected at 75°C	RATING (S, P, C)
HV	Highest	H1-H0		mΩ
		H2-H0		mΩ
		H3-H0		mΩ
HV	N	H1-H0		mΩ
		H2-H0		mΩ
		H3-H0		mΩ
HV	Lowest	H1-H0		mΩ
		H2-H0		mΩ
		H3-H0		mΩ
LV	-	X1-X0		mΩ
		X2-X0		mΩ
		X3-X0		mΩ
TV	-	y_y_-		mΩ
		y_y_-		mΩ
		y_y_-		mΩ

Standards Used: _____

Remarks: _____

POWER TRANSFORMER TEST DATA

Page 3 of 3

VI. Oil Dielectric Breakdown Voltage, ASTM D1816

SOURCE OF SAMPLE	TEST NUMBER					AVERAGE (X)	TEMP °C	RATING (S, P, C)
	1	2	3	4	5			
Main Tank								
LTC								

Standards Used: _____

Remarks: _____

Overall Remarks: _____

Tested by :

Concurred by :

Contractor - Test Engineer

Owner's Representative

TEST INSTRUMENTS:

(Eqpt.ID/Make/Model/SN/
Date of last calibration)

Legend:

S - Satisfactory
P - Poor
C - Critical