

**STATION SERVICE TRANSFORMER**  
(13.8 kV and below)

Page

1 of 2

**TEST DATA**

**Test Data No.** \_\_\_\_\_  
 Station \_\_\_\_\_  
 Equipment ID \_\_\_\_\_  
 Date of Test \_\_\_\_\_  
 Make \_\_\_\_\_  
 Serial No \_\_\_\_\_  
 Tap Changer Type \_\_\_\_\_

MVA \_\_\_\_\_  
 kV HV \_\_\_\_\_ Y [ ]  $\triangle$  [ ]  
 LV \_\_\_\_\_ Y [ ]  $\triangle$  [ ]  
 Winding Connection \_\_\_\_\_  
 % Impedance \_\_\_\_\_  
 Year Manufactured \_\_\_\_\_

**I. TRANSFORMER TURNS RATIO TEST**

HV		LV		Comp Ratio	<u>1U1V/ 2u2n</u>	%E	<u>1V1W/ 2v2n</u>	%E	<u>1W1U/ 2w2n</u>	%E	Rating (S, P, C)
Tap	Volts	Tap	Volts								

Standards Used: \_\_\_\_\_

Remarks: \_\_\_\_\_

**II. INSULATION RESISTANCE TEST**

PARTS MEASURED	TEST kV	MEGOHMS		MΩ/KV	POLARIZATION INDEX	RATING (S, P, C)
		1 MIN	10 MIN			
HV-Case						
HV-LV						
LV-Case						

Standards Used: \_\_\_\_\_

Remarks: \_\_\_\_\_

**III. WINDING RESISTANCE TEST**

WINDING	TAP	WINDING MEASURED	RESISTANCE (mΩ) corrected at 75°C	RATING (S, P, C)
HV	Highest			mΩ
				mΩ
				mΩ
HV	N			mΩ
				mΩ
				mΩ
HV	Lowest			mΩ
				mΩ
				mΩ
TV				mΩ
				mΩ
				mΩ
				mΩ

Standards Used: \_\_\_\_\_

Remarks: \_\_\_\_\_

# STATION SERVICE TRANSFORMER TEST DATA

Page 2 of 2

## IV. OIL DIELECTRIC BREAKDOWN VOLTAGE, ASTM D1816

SOURCE OF SAMPLE	TEST NUMBER					AVERAGE (X)	TEMP °C	RATING (S, P, C)
	1	2	3	4	5			
Main Tank								
LTC								

Standards Used: \_\_\_\_\_

Remarks: \_\_\_\_\_  
\_\_\_\_\_

Overall Remarks: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Tested by :

Concurred by :

\_\_\_\_\_  
Contractor - Test Engineer

\_\_\_\_\_  
Owner's Representative

## TEST INSTRUMENTS:

(Eqpt.ID/Make/Model/SN/  
Date of last calibration)

\_\_\_\_\_  
\_\_\_\_\_

## Legend:

S - Satisfactory  
P - Poor  
C - Critical