





SAMPLE NO. 2

RELAY	MAKE	FUNCTION
LINE PROT MAIN 1		87L 21 67G 51/51N SOTF FL TR
LINE PROT MAIN 2		85 21 67G 51/51N SOTF FL TR
BREAKER FAILURE PROT.		79 25/27 50BF FR
SPS PROT. SYSTEM		32 FR

NOTE: All equipment labels should conform with the NGCP SEIL labeling standard.